



Office of the Chief Fire Officer  
Bengaluru-East Zone  
Karnataka Fire & Emergency Services  
No. 04, Commissariat Road, Bengaluru-560 025.



No. 1528/CFO/Bng-East/FSCR/2021

Dated: 28-12-2021.

"Annexure-2"

To,  
The Secretary,  
Chistiya International School,  
Near Gunjur Bus Stop,  
Via Varthur, Bangalore 560 087.

Sir,

**Sub :** Issue of "Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at "Chistiya International School, Near Gunjur Bus Stop, Via Varthur, Bangalore 560 087" - reg.

**Ref :** 1) This office FSR No.366/CFO/Bng-East/FSR/2021, Date:20-05-2021.  
2) Your request letter dated : 22-12-2021.  
3) Inspection report no: 75/DFO/SRFS/FSR/2021, Date: 24-12-2021.

<<<>>>


With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "Chistiya International School, Near Gunjur Bus Stop, Via Varthur, Bangalore 560 087" with a condition to fulfill the recommendations and compliance the same within 3 months.


With reference cited (2) above, the management of "Chistiya International School" had requested for the fire safety compliance report from our department. In this regard the District Fire Officer, Sarjapura Road Fire Station, Bangalore was re-inspected on 24-12-2021 and submitted the report to issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to "Chistiya International School, Near Gunjur Bus Stop, Via Varthur, Bangalore 560 087" Subject to proper maintenance of fire fighting installations in the good working conditions and impart 40% training part within 30 days from the date of issue of this report. "This report is valid up to 19-05-2022 and is renewable without fail"

Copy to: The District Fire Officer,  
Sarjapura Road Fire Station,  
Bangalore.

Yours faithfully,

  
Chief Fire Officer 28/12/21  
Bengaluru East Zone  
Bengaluru

  
f.s. Navaneeth  
SECRETARY

  
PRINCIPAL

CHISTIYA INTERNATIONAL SCHOOL  
Gunjur, Via Varthur, Bangalore-560087

CHISTIYA INTERNATIONAL SCHOOL  
Gunjur Bus Stop, Via Varthur, Bangalore -560087

Date: .....



OFFICE OF THE DISTRICT FIRE OFFICER  
SARJAPUR ROAD FIRE STATION  
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO:75 /DFO/SRFS/BNG-2021.

To,  
The Chief fire officer  
Bangaluru east zone  
Karnataka state fire & emergency service  
Bangaluru-560025.

**ANNEXURE-B**  
**Group B Educational Buildings**

Sub: Issue of 'Fire Compliance Report' to M/s.Chistiya International School, Near Gunjur Bus Stop. Via Varthur Bangalore – 560 087. Inspection report Submitted.


Ref: No. 1528/CFO/BNG-East/2021. Dated: 22/12/2021.


><<>\*@\*<<><

With reference to the subject cited above, I submit to state that the premises M/s. Chistiya International School, Near Gunjur Bus Stop. Via Varthur Bangalore – 560 087. Was inspected by me on 24-12-2021 for suggesting fire prevention, fire fighting & evacuation measures. The details are as follows:-

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	:	The Authorized Signatory, M/s. Chistiya International School, Near Gunjur Bus Stop. Via Varthur Bangalore – 560 087.
02	Name and Address of the premises.	:	M/s. Chistiya International School, Near Gunjur Bus Stop. Via Varthur Bangalore – 560 087.
03	Name and address of the Building owner	:	M/s. Chistiya International School, Near Gunjur Bus Stop. Via Varthur Bangalore – 560 087.
04	Number of buildings	:	One building



  
PRINCIPAL

CHISTIYA INTERNATIONAL SCHOOL  
Gunjur, Via Varthur, Bangalore-560087

Scanned with CamScanner  
  
SECRETARY

CHISTIYA INTERNATIONAL SCHOOL  
Gunjur Bus Stop, Via Varthur, Bangalore -56


	kg/cm <sup>2</sup> .	capable of delivering 900 liters of water per minute.	
10.	Escape routes	Escape routes have been Marked in Which visibly to guide the students make to safer Places.	Complied.
11.	Fire order	Four Numbers of Fire order board has been displayed near each staircase of ground floor with <b>emergency Telephone Numbers of Sarjapur Road Fire Station i.e. 25746166 &amp; 101</b> and telephone numbers of nearest Ambulance Service & Management.	complied
12	No Smoking board.	No Smoking board shall be displayed.	Complied
13.	Fire fighting training	Not trained	The 40% of staff or employees Should Be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29.

From the above details it is clear that the applicant has been incorporated all the required fire prevention and fire fighting measures in the drawings. Hence herewith recommended to issue "**Fire Compliance Report**" for the low rise Educational Building at M/s. Chistiya International School, Near Gunjur Bus Stop. Via Varthur Bangalore – 560 087.

❖ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied With mandatorily.

*Submitted for your kind perusal and necessary action.*

Yours faithfully

  
**DISTRICT FIRE OFFICER**  
 Sarjapura Road Fire Station  
 Bengaluru-560 035.

  
 Scanned with CamScanner  
**SECRETARY**

  
**PRINCIPAL**  
**CHISTIYA INTERNATIONAL SCHOOL**  
 Gunjur, Via Varthur, Bangalore-560087

**CHISTIYA INTERNATIONAL SCHOOL**  
 Gunjur Bus Stop, Via Varthur, Bangalore -560087